



Extruded Curb See
 Detail SD-09 (Curb & Gutter may
 be used in place of Extruded
 Curb See Detail SD-10)

MINIMUM REQUIREMENTS:

- 1 1 1/2" ASPHALTIC CONCRETE SURFACE (GRADING E) ITEM NO. 411-01.11
- 2 TACK COAT (RS-2) ITEM NO. 403-01
- 3 2" ASPHALTIC CONCRETE BASE (GRADING B) ITEM NO. 307-01.06
- 4 PRIME COAT (AE-P) ITEM NO. 402-01
- 5 8" STONE (GRADING D PUG MILL MIX) ITEM NO. 303-01
- 6 APPROVED COMPACTED SUBGRADE

ITEM NUMBERS ARE TO MEET TDOT SPECIFICATIONS

Notes:

Additional right-of-way may be required near intersections.

Elements of this typical section may be revised if approved by the City Engineer.



CITY OF

COLUMBIA
 TENNESSEE

RESIDENTIAL LOCAL STREET

(NTS)

DATE
 9-10-2014

DWG. NO.

SD-04